



White Letters

12"

Red Background



- The sign will be located within 12" of the 10" bell/strobe.
- The sign shall be either above or below the bell/strobe.
- Location is to be approved by the Fire Marshal.



City of Bothell
 Community Risk Reduction

Approved By:
[Signature]
 Fire Marshal
 Date:
 July 25, 2012

Fire Alarm
 Notification Sign

Standard
 Detail
905
 Revision Date
 July 2012